

Lightning Protection Standards



Richard Bouchard

- Employed With UL for 24 Years
- Technical Advisor for UL's Lightning Protection Services
- Member of NFPA 780 Technical Panel
- Certification for Residential Building Inspector to the International Building Code for Single and Multi Family Dwellings Pending

Objectives

- Standards Actively Used Design and Inspection
 - NFPA 780
 - UL 96A
 - UFC 3-570-01
 - AFMAN 91-201
 - NAVSEA OP-5, Vol. 1
 - DA Pamphlet 385-64

- First Three Used for Ordinary Buildings

- Last Three Referenced for Ordnance / Explosive Facilities



Standard Used for System Design

- NFPA 780
- UFC 3-570-01

Standard Used for System Inspection

- UL 96A

Relationship Between the Standards

- NFPA 780
 - Base Document Used by UFC 3-570-01 & UL96A
 - UL96A Designed to Meet All the Min Requirements
 - UFC 3-570-01 Provides Guidance for Areas Not Covered in NFPA 780

- UL96A
 - Intended As an Inspection Standard
 - Defined Requirements
 - Less Interpretations.



Relationship Between the Standards

- UFC 3-570-01
 - Unified Basic Requirements Between Service Branches
 - Expansion of Requirements for Special Types of Structures
 - Guideline Requirements for Ordnance / Explosive Facilities

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - Section 5-3 refers to NFPA 780 Appendix H for risk assessment to identify structures not needing coverage.
 - 5-4.1 Capped air terminals are not permitted.
 - 5-4.1.2 Air Terminals gives specific distances for exhausting hazardous vapors
 - Air terminals installed on “rubber” (EPDM) type roofs

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - 5-4.1.3 Conductors.
 - Bolted Connections Are Not Allowed on the Roof and Down Conductors.
 - Roof and Down Conductors Shall Be Exothermically Welded or Shall Use High Compression Fittings
 - There Are No Listed High Compression Fittings Listed by UL for This Application.
 - 5-4.2 **Mast System.**
 - The down conductors need to be protected from grade level to a point 3 m (10ft) above grade.

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - 5-4.2.7 Joint Design.
 - Not covered in NFPA 780
 - 5-4.2.8 Joint Test.
 - Not covered in NFPA 780
 - 5-4.4 Faraday Shield System.
 - Not covered in NFPA 780
 - 5-5 NONCONVENTIONAL SYSTEMS.
 - Dissipation Arrays and Those Using Early Streamer Emission Air Terminals Are Not Acceptable and Are Not Be Used.

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - 5-6.2 Bonding Installation Guidelines For Design And Construction.
 - Basic Requirements for Bonding of LPS Are in AFI 32-1065 and NFPA 780.
 - 5-7.1 Ground Resistance.
 - Not Covered in NFPA 780 With a Specific Value but Techniques.
 - 5-7.2
 - Plate Electrodes Is Discouraged

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - 5-10.2 Reinforced Concrete Buildings.
 - Reinforcement Steel May Be Used for Down Conductors, in Conformance With NFPA 780. This Is Not Allowed in NFPA 780
 - 5-10.3 Steel Frame Building With Non-conducting Roof and Sides.
 - At Least One Steel Column Must Be Grounded at Each Corner of the Building.
 - 5-10.4 Through 5-10.6
 - Installation Techniques Not Covered in NFPA 780

Major Differences Between the Standards

- UFC 3-570-01 & NFPA 780
 - 5-10.9 Post Tensioning Systems.
 - The Post Tension Rods Shall Not Be Used As a Path for Lightning to Ground.
 - 5-10.10 Through 5-10.20
 - These Cover Special Types of Ordinary Structures

Questions



Slide 14

Thank You for Attending