

# Advancing the Propane Fast Cookoff Burner and Testing



Ephraim Washburn, Ross Falen, and Jeff Prevost  
NAWCWD, China Lake, CA

David Hubble and Jon Yagla  
NSWCDD, Dahlgren, VA



2018 Insensitive Munitions and Energetic  
Materials Technology Symposium  
Portland, Oregon



# Background



- Fast cookoff is an international standard safety test required for all explosive ordnance
- Environmental concerns
  - Tests use large pools of hydrocarbon fuel such as JP5, JP8, kerosene, etc.
  - Emissions from one test: 200 kg CO, 35 kg NO<sub>x</sub>, 30 kg SO<sub>x</sub>, 225 kg soot, 125 kg unburned HC, and 20,000 kg CO<sub>2</sub>
  - Ground water concerns
  - Public relations
- Propane viable substitute fuel
  - Gas at atmospheric conditions
  - Cleaner burning
  - Readily available
  - Sufficient heat content





# Outline



- Calibration of burner at China Lake, CA
- Testing of ordnance items in burner at Dahlgren, VA and China Lake, CA
- Technical drawing package of 3.7 m by 3.7 m propane burner



# 6.1 m by 4.6 m Propane Burner



- Constructed a 6.1 m by 4.6 m burner: Hoped for better engulfment on sides compared to previous 6.1m by 3.0 m burner
- Tested burner November 2016
  - Flame not as high as previous testing
  - Not enough fuel to burner
  - Reduced burner to 4.6 m by 4.6 m
- Heat fluxes sufficient but not consistent
  - Lower than desired
  - Flame not as high as before
- Reduced pressure drop from propane tank increased propane flow, but still not sufficient
- Added heating blanket to propane tank
  - Temperature in tank determines pressure
  - Winter testing creates low pressures and variable flows
  - Installed Model GCW1KS Rev C from Powerblanket®
  - Maintained temperature in propane tank at 32 °C

# Modified 6.1 m by 4.6 m Burner

- Burner changes
  - 6.1 m by 4.6 m burner with 3.0 m pipes
  - Alternating side of entrance
  - Overlap in center 1.5 m
  - 3.0 m pipes provide for ease of hole drilling with water drilling facility
  - Fuel directed to center





# Modified 6.1 m by 4.6 m Burner






## Qualitative Results





## Quantitative Results




Wall

Temperature Measurement Set Up




Wall


Heat Flux Measurement Set Up



- All temperatures above 800 °C
- Standard deviation of average local temperatures less than 10% of overall average temperature



- All heat fluxes above 80 kW/m<sup>2</sup>
- Higher heat fluxes representative of large jet fuel pool fire
- Repeatable: two tests at location 8
  - 1<sup>st</sup> test: 167, 168, 160, 150 kW/m<sup>2</sup>
  - 2<sup>nd</sup> test: 163, 162, 155, 147 kW/m<sup>2</sup>





# Modified 6.1 m by 4.6 m Burner



- Large test volume where thermal requirements are met: 4.3 m by 1.8 m by 1.5 m
- Replaced 3790 liter tank with 14760 liter tank
  - US regulations on propane tank greater than 15140 liters
  - Increased burn time from ~13 minutes to ~ 50 minutes
- Performed FCO test with 227 kg (500 lb) class bomb

# Modified 6.1 m by 4.6 m Burner

- FCO tested 227 kg (500 lb) class bomb in both pool fuel fire and propane burner

Pool Fuel Fire FCO    Pretest



Post-test



Propane FCO    Pretest



Post-test





# Modified 6.1 m by 4.6 m Burner



- FCO tested 227 kg (500 lb) class bomb in both pool fuel fire and propane burner
- Largest item tested in propane burner to date
- Propane burner was able to produce a flame that was large enough to engulf both A-frame and ordnance item
- Learned the importance of propane valve electrical system
  - A corroded relay led to a test stoppage and retest of item
  - Contingency plan needed for stoppage of burner during test before reaction
- No need to plan for same day fuel delivery
  - Provided flexibility in testing
  - Aided dealing with wind variability
- Initial results show similar reaction of bomb in pool fuel fire and propane burner


- Propane FCO test was performed on an ammo can of medium ammunition cartridges
- Ammo can contained 110 training and practice (TP) cartridges (live propellant, inert projectile)
- This was the first test in the propane FCO burner that contained multiple energetic items
- Concern that items cooking off while in contact with the burner tubes would cause damage





12:44:45.550

- Item was engulfed in flame for 14:40
- First reaction occurred 2:30 into test and the last audible reaction occurred 9:10 after ignition
- Burner remained on for 5 minutes after last audible reaction
- Test produced a large number of fragments, 64 of which traveled beyond 15 m (50 ft)
  - Only fragments beyond 15 m were catalogued and weighed



- Fragments were collected and catalogued as if going to MREB
- Majority of fragments remained within the burner and the workers were happy with how easy collection was compared to JP5 test



Exited Burner  
but <15 m

Remained inside  
burner

Greater  
than 15 m



- Test produced 64 fragments that traveled further than 15 m
- None exceeded the 20 Joule threshold resulting in a type [V] assessment




- Test was scored a type IV in the liquid fuel test and a type [V] in the propane test
- Debris map was very similar, barely exceeded 20J in the liquid test, just under 20J in propane test
- No quenching of ordnance items in propane test (shorter duration of reactions)

## Propane

Average Temp: 1702°F

Time to 1<sup>st</sup> reaction: 2:30

Duration of reactions: 6min, 40s




## Jet Fuel

Average Temp: 1727°F

Time to 1<sup>st</sup> reaction: 1:40




Duration of reactions: 13min, 30s





- Fragments produced during the test easily punctured the ammunition can and the side shields
- Reactions of items in contact with the burner tubes did cause some slight denting but no punctures occurred



- A technical drawing package was developed to aid in the dissemination of the burner
- Since the propane burner was developed as a series of prototypes with refinements, no official drawings existed



- The drawing package also includes detailed plumbing schematics
- These incorporate all the lessons that were learned through trial and error
- The drawing package provides all the information needed to fabricate the 3.7 m by 3.7 m propane burner in use at Dahlgren



- A modified 6.1 m by 4.6 m propane burner was designed, built, and calibrated
  - Large engulfing flame
  - Meets temperature and heat flux requirements
- 227 kg class bomb tested in modified 6.1 m by 4.6 m propane burner
- Ammo can of medium caliber ammunition tested in 3.7 m by 3.7 m propane burner
  - Similar result to liquid fuel fire test
  - Easy clean up
  - Multiple reactions did not damage burner
- Technical drawing package for 3.7 m by 3.7 m propane burner developed and available upon request



# Acknowledgments



Funded by:

The Environmental Security Technology Certification Program (ESTCP)



The Insensitive Munitions Advanced Development (IMAD) Program

